

MOTOR DATA SHEET

Motor type: 2SIE250M4



26-04-2025

tor type. **ZSIEZSO**

Series: IE2

| | ELECTRICAL PARAMETERS | | | | | | | | | | | | | | | | |
|-----|-----------------------|----|----|----|------|----|------|-----|------|------|------|--------|-------------|-------|-------|----------------|---------|
| U | CONN. | f | ŀ | D | Duty | I | n | Т | TL/T | TB/T | IL/I | Effici | ency at loa | d [%] | Power | r factor at le | oad [-] |
| V | - | Hz | kW | HP | - | А | rpm | Nm | - | - | - | 2/4 | 3/4 | 4/4 | 2/4 | 3/4 | 4/4 |
| 400 | Δ | 50 | 55 | 75 | S1 | 94 | 1482 | 354 | 1.9 | 2.4 | 5.9 | 93.2 | 93.7 | 93.5 | 0.84 | 0.89 | 0.90 |
| 690 | Y | 50 | 55 | 75 | S1 | 55 | 1482 | 354 | 1.9 | 2.4 | 5.9 | 93.2 | 93.7 | 93.5 | 0.84 | 0.89 | 0.90 |

| GENERAL DATA | | | | | | |
|----------------------------|---------------------------------|--------------------------------------|-----------|--|--|--|
| Efficiency class | IE2 | Sound pressure level [dB] | 75 | | | |
| Frame size | 250 | Sound power level [dB] | 85 | | | |
| Number of poles | 4 Terminal box position | | top | | | |
| Starting method | DOL or Y/Δ | Possibility of terminal box rotation | yes | | | |
| Insulation class | F Bearing on D-side | | 6315C3 | | | |
| Frequency converter supply | yes Bearing on ND-side | | 6315C3 | | | |
| Mounting arrangement | IMB3/B5/B35 Bearings regreasing | | yes | | | |
| Cooling method | IC411 | Housing - material | cast iron | | | |
| Weight (IMB3) [kg] | 478 | Feet - material | cast iron | | | |
| Moment of inertia [kgm2] | 1.0 | Bearing shields - material | cast iron | | | |
| Direction of rotation | CW/CCW | Painting | RAL5010 | | | |
| Degree of protection | IP55 | Climatic execution | Ν | | | |

| ENVIRONMENTAL CONDITIONS | | | | | | | |
|--------------------------|-----------|------------------------------|------------|--|--|--|--|
| Ambient temperature [°C] | up to +40 | Altitude above sea level [m] | up to 1000 | | | | |
| Relative humidity [%] | up to 95 | | | | | | |

| ACCESSORY | | | | | | |
|--------------------------------|---------|---------------------------------|-----------|--|--|--|
| Number of terminals or cables | 6 | Temperature sensors in bearings | on demand | | | |
| Cable glands/inlets | 2 + 1 | Winding heaters | on demand | | | |
| Temperature sensors in winding | 3 x PTC | Optional accessories | on demand | | | |

| STANDARDS |
|-------------|
| IEC 60034-1 |
| |

CERTIFICATES

on demand



As part of our development program, we reserve the rights to alter or amend any of the specifications without giving prior notice.

Copyright © 2025 Cantoni Group www.cantonigroup.com