

MOTOR DATA SHEET



26-04-2025

Motor type: PSg160L-4

Series: IE1

| ELECTRICAL PARAMETERS | | | | | | | | | | | | | | | | | |
|-----------------------|-------|----|------|----|------|------|------|--------|------|------|------|--------|-------------|-------|-------|---------------|---------|
| U | CONN. | f | ŀ | 0 | Duty | I | n | Т | TL/T | TB/T | IL/I | Effici | ency at loa | d [%] | Power | r factor at l | oad [-] |
| V | - | Hz | kW | HP | - | А | rpm | Nm | - | - | - | 2/4 | 3/4 | 4/4 | 2/4 | 3/4 | 4/4 |
| 400 | Δ | 50 | 18.5 | 25 | S1 | 35.0 | 1455 | 121.43 | 2.3 | 2.9 | 7.5 | 89.6 | 90.1 | 89.7 | 0.70 | 0.80 | 0.85 |
| 690 | Y | 50 | 18.5 | 25 | S1 | 20.3 | 1455 | 121.43 | 2.3 | 2.9 | 7.5 | 89.6 | 90.1 | 89.7 | 0.70 | 0.80 | 0.85 |

| GENERAL DATA | | | | | | |
|----------------------------|-------------------------|--------------------------------------|------------|--|--|--|
| Efficiency class | - | Sound pressure level [dB] | 61 | | | |
| Frame size | 160 | Sound power level [dB] | 71 | | | |
| Number of poles | 4 Terminal box position | | top | | | |
| Starting method | DOL or Y/Δ | Possibility of terminal box rotation | yes | | | |
| Insulation class | F Bearing on D-side | | 6309 2Z C3 | | | |
| Frequency converter supply | yes | Bearing on ND-side | 6309 2Z C3 | | | |
| Mounting arrangement | IMB3/B5/B35 | Bearings regreasing | on demand | | | |
| Cooling method | IC411 | Housing - material | cast iron | | | |
| Weight (IMB3) [kg] | 130 | Feet - material | cast iron | | | |
| Moment of inertia [kgm2] | 0.1031 | Bearing shields - material | cast iron | | | |
| Direction of rotation | CW/CCW | Painting | RAL5010 | | | |
| Degree of protection | IP55 | Climatic execution | Ν | | | |

| ENVIRONMENTAL CONDITIONS | | | | | | | |
|--------------------------|-----------|------------------------------|------------|--|--|--|--|
| Ambient temperature [°C] | up to +40 | Altitude above sea level [m] | up to 1000 | | | | |
| Relative humidity [%] | up to 95 | | | | | | |

| ACCESSORY | | | | | | |
|--------------------------------|-----------|---------------------------------|-----------|--|--|--|
| Number of terminals or cables | 6 | Temperature sensors in bearings | on demand | | | |
| Cable glands/inlets | 1 | Winding heaters | on demand | | | |
| Temperature sensors in winding | on demand | Optional accessories | on demand | | | |

| STANDARDS |
|-------------|
| IEC 60034-1 |
| |

CERTIFICATES

on demand



As part of our development program, we reserve the rights to alter or amend any of the specifications without giving prior notice.

Copyright © 2025 Cantoni Group www.cantonigroup.com