

MOTOR DATA SHEET

Motor type: (E)cSTe(b)160L8-IE3



07-06-2025

| Series: | ΕI | | | IE3 |
|---------|----|------|-------|-----|
| series: | ГL | AMER | -KUUF | IED |

| | ELECTRICAL PARAMETERS | | | | | | | | | | | | | | | | |
|-----|-----------------------|----|-----|----|------|------|-----|-----|------|------|------|--------|-------------|-------|-------|----------------|---------|
| U | CONN. | f | ŀ | D | Duty | I | n | Т | TL/T | TB/T | IL/I | Effici | ency at loa | d [%] | Power | r factor at le | oad [-] |
| v | - | Hz | kW | HP | - | А | rpm | Nm | - | - | - | 2/4 | 3/4 | 4/4 | 2/4 | 3/4 | 4/4 |
| 400 | Y | 50 | 7.5 | 10 | S1 | 16.1 | 710 | 101 | 2.0 | 2.6 | 5.4 | 87.9 | 88.5 | 87.3 | 0.60 | 0.71 | 0.77 |

| GENERAL DATA | | | | | | | |
|----------------------------|-------------|--------------------------------------|------------|--|--|--|--|
| Efficiency class | IE3 | Sound pressure level [dB] | - | | | | |
| Frame size | 160 | Sound power level [dB] | - | | | | |
| Number of poles | 8 | Terminal box position | top | | | | |
| Starting method | DOL | Possibility of terminal box rotation | yes | | | | |
| Insulation class | F | Bearing on D-side | 6309 2Z C3 | | | | |
| Frequency converter supply | on demand | Bearing on ND-side | 6309 2Z C3 | | | | |
| Mounting arrangement | IMB3/B5/B35 | Bearings regreasing | on demand | | | | |
| Cooling method | IC411 | Housing - material | cast iron | | | | |
| Weight (IMB3) [kg] | 240 | Feet - material | cast iron | | | | |
| Moment of inertia [kgm2] | 0.102 | Bearing shields - material | cast iron | | | | |
| Direction of rotation | CW/CCW | Painting | RAL5010 | | | | |
| Degree of protection | IP55 | Climatic execution | N | | | | |

| ENVIRONMENTAL CONDITIONS | | | | | | |
|--------------------------|--------------------|------------------------------|------------|--|--|--|
| Ambient temperature [°C] | from -20 up to +40 | Altitude above sea level [m] | up to 1000 | | | |
| Relative humidity [%] | up to 95 | | | | | |

| ACCESSORY | | | | | |
|--------------------------------|-----------|---------------------------------|-----------|--|--|
| Number of terminals or cables | 3 | Temperature sensors in bearings | on demand | | |
| Cable glands/inlets | 1 | Winding heaters | on demand | | |
| Temperature sensors in winding | on demand | Optional accessories | on demand | | |

| STANDARDS |
|--|
| IEC 60034-1, IEC 60079-0, IEC 60079-1, IEC 60079-7 |

| CERTIF | CATEC |
|--------|-------|
| | LAIES |

ATEX, EAC, BiH

| | ADDITIONAL INFO | |
|------------|---|--|
| Ex marking | II 2G Ex.db (eb) IIB T5 Gb lub na życzenie II 2G Ex db (eb) IIC T5 Gb | |

As part of our development program, we reserve the rights to alter or amend any of the specifications without giving prior notice.

Copyright © 2025 Cantoni Group www.cantonigroup.com

anta OUP